APPENDIX B-1

Summary of Water Limits, Guidelines, and Standards

TABLE B-1A
West Valley Demonstration Project State Pollutant Discharge Elimination System (SPDES) Sampling Program

Outfall	Parameter	Daily Maximum Limit[a]	Sample Frequency
001 (Process and Storm Wastewater)	Flow	Monitor	2/discharge
	Aluminum, total	14.0 mg/L	1/discharge
	Ammonia (NH_3)	Monitor	2/discharge
	Arsenic, dissolved	0.15 mg/L	1/discharge
	BOD_5	10.0 mg/L	2/discharge
	Iron, total	Monitor	2/discharge
	Zinc, total recoverable	0.48 mg/L	2/year
	Solids, total suspended	45 mg/L	2/discharge
	Cyanide, amenable to chlorination	0.022 mg/L	2/year
	Settleable solids	0.3 mL/L	2/discharge
	pH (range)	6.5–8.5 SU	1/discharge
	Oil and grease	15.0 mg/L	2/discharge
	Sulfate (as S)	Monitor	2/discharge
	Sulfide, dissolved	0.4 mg/L	1/discharge
	Manganese, total	2.0 mg/L	2/year
	Nitrate (as N)	Monitor	2/discharge
	Nitrite (as N)	0.1 mg/L	2/discharge
	Chromium, total recoverable	0.3 mg/L	2/year
	Chromium, hexavalent, total recoverable	0.011 mg/L	1/year
	Cadmium, total recoverable	0.002 mg/L	1/year
	Copper, total recoverable	0.030 mg/L	2/year
	Copper, dissolved	Monitor	2/year
	Lead, total recoverable	0.006 mg/L	4/year
	Nickel, total recoverable	0.14 mg/L	2/year
	Dichlorodifluoromethane	0.01 mg/L	1/year
	Trichlorofluoromethane	0.01 mg/L	1/year
	3,3-dichlorobenzidine	0.01 mg/L	1/year
	Tributyl phosphate	32 mg/L	1/year
	Vanadium, total recoverable	0.014 mg/L	1/discharge
	Cobalt, total recoverable	0.005 mg/L	1/discharge
	Selenium, total recoverable	0.004 mg/L	2/discharge
	Hexachlorobenzene	0.02 mg/L	1/year
	Alpha - BHC	0.00001 mg/L	1/year
	Heptachlor	0.00001 mg/L	2/year
	Surfactants (as LAS)	0.4 mg/L	2/year
	Xylene	0.05 mg/L	1/year
	2-butanone	0.5 mg/L	1/year
	Total dissolved solids	Monitor	2/discharge
	Mercury, total	200 ng/L	2/discharge

[a] Daily average limitations are also identified in the permit but require only monitoring for all parameters except total aluminum (daily average limit - 7.0 mg/L); total suspended solids (daily average limit - 30 mg/L); BOD_5 for the sum of outfalls 001, 007, and 008 (daily average limit - 5.0 mg/L); and ammonia for the sum of outfalls 001 and 007 (daily average limit - 1.49 mg/L).

TABLE B-1A *(concluded)*
West Valley Demonstration Project State Pollutant Discharge Elimination System

Outfall	Parameter	Daily Maximum Limit[a]	Sample Frequency
01B (Internal Process Monitoring Point)	Flow	Monitor	weekly
	Mercury, total	10.0 µg/L	2/month
007 (Sanitary and Utility Wastewater)	Flow	Monitor	3/month
	Ammonia (as NH_3)	Monitor	3/month
	BOD5	10.0 mg/L	3/month
	Iron, total	Monitor	3/month
	Solids, total suspended	45 mg/L	3/month
	Solids, settleable	0.3 mL/L	weekly
	pH (range)	6.5–8.5 SU	weekly
	Nitrite (as N)	0.1 mg/L	3/month
	Oil and grease	15.0 mg/L	3/month
	Chlorine, total residual	0.1 mg/L	weekly
Sum of Outfalls 001, 007, and 008	Iron, total	0.30 mg/L	3/month
	BOD_5	Monitor	3/month
Sum of Outfalls 001 and 007	Ammonia (as NH_3)	2.1 mg/L	3/month
Pseudo-monitoring point (116)	Solids, total dissolved	500 mg/L	2/discharge
Storm Water Outfalls (semiannually; one outfall from each of the eight drainage basins)	pH	Monitor	1/rain event
	Oil and grease	15.0 mg/L	1/rain event

Outfall	Parameter	Action Level	Sample Frequency
001 (Process and Storm Wastewater)	Barium	0.5 mg/L	annual
	Antimony	1.0 mg/L	annual
	Chloroform	0.3 mg/L	annual
	Titanium	0.65 mg/L	semiannual
	Bromide	5.0 mg/L	quarterly
	Boron	2.0 mg/L	quarterly
007 (Sanitary and Utility Wastewater)	Chloroform	0.20 mg/L	annual

Note: Limits for point 008 (French Drain) are not listed because the point has been closed off since 2001.

[a] Daily average limitations are also identified in the permit but require only monitoring for all parameters except total aluminum (daily average limit - 7.0 mg/L); total suspended solids (daily average limit - 30 mg/L); BOD_5 for the sum of outfalls 001, 007, and 008 (daily average limit - 5.0 mg/L); and ammonia for the sum of outfalls 001 and 007 (daily average limit - 1.49 mg/L).

TABLE B-1B
New York State Water Quality Standards and Guidelines[a]

New York Water Quality Standards and Guidelines [a]						
Parameter	***Units***	***Class A***	***Class B***	***Class C***	***Class D***	***Class GA***
Gross Alpha[b]	pCi/L (µCi/mL)	15 (1.5E-08)	--	--	--	15 (1.5E-08)
Gross Beta[c]	pCi/L (µCi/mL)	1,000 (1E-06)	--	--	--	1,000 (1E-06)
Tritium (H-3)	pCi/L (µCi/mL)	20,000 (2E-05)	--	--	--	--
Strontium-90	pCi/L (µCi/mL)	8 (8E-09)	--	--	--	--
Alpha BHC	mg/L	0.000002	0.000002	0.000002	0.000002	0.00001
Aluminum, Dissolved	mg/L	0.10	0.10	0.10	--	--
Aluminum, Total	mg/L	--	--	--	--	--
Ammonia, Total as N	mg/L	0.09–2.1	0.09–2.1	0.09–2.1	0.67–29	2.0
Antimony, Total	mg/L	0.003	--	--	--	0.003
Arsenic, Dissolved	mg/L	0.050	0.150	0.150	0.340	--
Arsenic, Total	mg/L	0.050	--	--	--	0.025
Barium, Total	mg/L	1.00	--	--	--	1.00
Beryllium, Total	mg/L	0.003	[d]	[d]	--	0.003
Boron, Total	mg/L	10.0	10.0	10.0	--	1.00
Bromide	mg/L	2.00	--	--	--	2.00
Cadmium, Dissolved[e]	mg/L	--	--	--	--	--
Cadmium, Total	mg/L	0.005	--	--	--	0.005
Calcium, Total	mg/L	--	--	--	--	--
Chloride	mg/L	250	--	--	--	250
Chromium, Dissolved[e]	mg/L	--	--	--	--	--
Chromium, Total	mg/L	0.05	--	--	--	0.05
Cobalt, Total[f]	mg/L	0.005	0.005	0.005	0.110	--
Conductivity	µmhos/cm@25°C	--	--	--	--	--
Copper, Dissolved[e]	mg/L	--	--	--	--	--
Copper, Total	mg/L	0.20	--	--	--	0.20
Cyanide	mg/L	0.0052	0.0052	0.0052	0.22	0.200
Dissolved Oxygen (minimum)	mg/L	4.0	4.0	4.0	3.0	--
Fluoride[e]	mg/L	--	--	--	--	1.5
Hardness	mg/L	--	--	--	--	--
Iron and Manganese (sum)	mg/L	--	--	--	--	0.500
Iron, Total	mg/L	0.30	0.30	0.30	0.30	0.30

-- No applicable guideline or reference standard available

Note: All water quality and metals standards are presented in mg/L (ppm) to provide consistency in comparisons.

[a] Source: 6 NYCRR Parts 701–704; The most stringent applicable pathway (e.g., wildlife, aquatic, human health) values are reported.

[b] Gross alpha standard includes radium-226, but excludes radon and uranium; however WVDP results include these isotopes.

[c] Gross beta standard excludes strontium-90 and alpha emitters, however WVDP results include these isotopes.

[d] Beryllium standard for classes "B" and "C" are based on stream hardness values.

[e] Standards for these constituents vary according to stream location hardness values.

[f] Standards for cobalt, thallium, and vanadium are applicable to the acid-soluble fraction.

[g] Applies to the sum of those organic substances which have individual human health water source standards listed at 0.100 mg/L or less in 6 NYCRR Part 703.5

[h] pH shall not be lower than 6.5 or the pH of natural groundwater, whichever is lower, nor shall pH be greater than 8.5 or the pH of the natural groundwater, whichever is greater.

TABLE B-1B *(concluded)*
New York State Water Quality Standards and Guidelines[a]

New York Water Quality Standards and Guidelines [a]						
Parameter	***Units***	***Class A***	***Class B***	***Class C***	***Class D***	***Class GA***
Lead, Dissolved[e]	mg/L	--	--	--	--	--
Lead, Total	mg/L	0.050	--	--	--	0.025
Magnesium, Total	mg/L	35.0	--	--	--	35.0
Manganese, Total	mg/L	0.30	--	--	--	0.30
Mercury, Dissolved	mg/L	0.0000007	0.0000007	0.0000007	0.0000007	--
Mercury, Total	mg/L	0.0007	--	--	--	0.0007
Nickel, Dissolved[e]	mg/L	--	--	--	--	--
Nickel, Total	mg/L	0.10	--	--	--	0.10
Nitrate-N	mg/L	10.0	--	--	--	10.0
Nitrate + Nitrite	mg/L	10.0	10.0	10.0	10.0	10.0
Nitrite-N	mg/L	0.10	0.10	0.10	--	1.00
NPOC[g]	mg/L	0.10	--	--	--	--
Oil & Grease	mg/L	--	--	--	--	--
pH	SU	6.5–8.5[h]	6.5–8.5[h]	6.5–8.5[h]	6.0–9.5	6.5–8.5[h]
Potassium, Total	mg/L	--	--	--	--	--
Selenium, Dissolved	mg/L	0.0046	0.0046	0.0046	--	--
Selenium, Total	mg/L	0.01	--	--	--	0.01
Silver, Total	mg/L	0.05	--	--	--	0.05
Sodium, Total	mg/L	--	--	--	--	20.0
Solids, Settleable	mg/L	--	--	--	--	--
Solids, Total Dissolved	mg/L	500	500	500	--	500
Solids, Total Suspended	mg/L	--	--	--	--	--
Sulfate	mg/L	250	--	--	--	250
Sulfide (undissociated form)	mg/L	0.002	0.002	0.002	--	0.050 (as HS)
Surfactants (as LAS)	mg/L	0.04	0.04	0.04	--	--
Thallium, Total[f]	mg/L	0.0005	0.008	0.008	0.020	0.0005
Titanium, Total	mg/L	--	--	--	--	--
TOX (total organic halides)[g]	mg/L	0.10	--	--	--	--
Vanadium, Total[f]	mg/L	0.014	0.014	0.014	0.190	--
Zinc, Dissolved[e]	mg/L	--	--	--	--	--
Zinc, Total	mg/L	2.00	--	--	--	2.00

-- No applicable guideline or reference standard available

Note: All water quality and metals standards are presented in mg/L (ppm) to provide consistency in comparisons.

[a] Source: 6 NYCRR Parts 701–704; The most stringent applicable pathway (e.g., wildlife, aquatic, human health) values are reported.

[b] Gross alpha standard includes radium-226, but excludes radon and uranium; however WVDP results include these isotopes.

[c] Gross beta standard excludes strontium-90 and alpha emitters, however WVDP results include these isotopes.

[d] Beryllium standard for classes “B” and “C” are based on stream hardness values.

[e] Standards for these constituents vary according to stream location hardness values.

[f] Standards for cobalt, thallium, and vanadium are applicable to the acid-soluble fraction.

[g] Applies to the sum of those organic substances which have individual human health water source standards listed at 0.100 mg/L or less in 6 NYCRR Part 703.5

[h] pH shall not be lower than 6.5 or the pH of natural groundwater, whichever is lower, nor shall pH be greater than 8.5 or the pH of the natural groundwater, whichever is greater.

TABLE B-1C
New York State Department of Health/U.S. Environmental Protection Agency Potable Water MCLs, MCLGs, and Raw Water Standards

Parameter	*Units*	*NYSDOH or EPA MCL* [a]	*EPA MCLG* [b]	*NYSDOH Raw Water Standards* [c]
Gross Alpha	pCi/L (µCi/mL)	15 (1.5E-08)[d]	0	--
Gross Beta	pCi/L (µCi/mL)	50 (5E-08)[e]	0	1,000 (1E-06)
Tritium (H-3)	pCi/L (µCi/mL)	20,000 (2E-05)	--	--
Strontium-90	pCi/L (µCi/mL)	8 (8E-09)	--	10 (1E-08)
Antimony, Total	mg/L	0.006	0.006	--
Arsenic, Total	mg/L	0.05	--	0.05
Barium, Total	mg/L	2.00	2.00	1.0
Beryllium, Total	mg/L	0.004	0.004	--
Cadmium, Total	mg/L	0.005	0.005	0.01
Chromium, Total	mg/L	0.10	0.10	--
Conductivity	µmhos/cm@25°C	--	--	--
Copper, Total	mg/L	1.3	1.3	<0.2
Cyanide	mg/L	0.2	0.2	<0.1
E. Coli	NA	one positive sample	0	--
Fluoride	mg/L	2.2	--	<1.5
Free Residual Chlorine	mg/L	0.02 (min) 4.0 (max)	--	--
Haloacetic Acids-Five (5)	mg/L	0.060	--	--
Iron, Total	mg/L	0.3	--	--
Lead, Total	mg/L	0.015	0	0.05
Mercury, Total	mg/L	0.002	0.002	0.005
Nickel, Total	mg/L	--	--	--
Nitrate-N	mg/L	10	10	--
pH	SU	--	--	6.5–8.5
POC (Principle Organic Contaminant)	mg/L	--	0.0005	--
Selenium, Total	mg/L	0.05	0.05	0.01
Solids, Total Dissolved	mg/L	--	--	500
Thallium, Total	mg/L	0.002	0.0005	--
Total Coliform	NA	2 or more positive samples	0	--
Total Trihalomethanes	mg/L	0.080	--	--
Turbidity	NTU	1 (max)	--	

-- No applicable guideline or reference standard available
Note: All water quality and metals standards are presented in mg/L (ppm) to provide consistency in comparisons.
NA - Not applicable

[a] MCL - Listed is NYSDOH or EPA Maximum Contaminant Level. Sources: 40 CFR 141 and/or 5 NYCRR 5-1.52, whichever is more stringent.
[b] MCLG - Maximum Contaminant Level Goal (non-enforceable) as listed in 40 CFR Part 141
[c] Source: 10 NYCRR Part 170.4
[d] Alpha guideline includes radium-226, but excludes uranium; however, WVDP results include these isotopes.
[e] Average annual concentration assumed to produce a total body organ dose of 4 mrem/year

TABLE B-1D
U.S. Department of Energy Derived Concentration Guides (DCGs)[a] in Ingested Water

Radionuclide	*Units*	*Concentration in Ingested Water*
Gross Alpha (as Am-241)[b]	µCi/mL	3E-08
Gross Beta (as Sr-90)[b]	µCi/mL	1E-06
Tritium (H-3)	µCi/mL	2E-03
Carbon-14 (C-14)	µCi/mL	7E-05
Potassium-40 (K-40)	µCi/mL	7E-06
Cobalt-60 (Co-60)	µCi/mL	5E-06
Strontium-90 (Sr-90)	µCi/mL	1E-06
Technetium-99 (Tc-99)	µCi/mL	1E-04
Iodine-129 (I-129)	µCi/mL	5E-07
Cesium-137 (Cs-137)	µCi/mL	3E-06
Europium-154 (Eu-154)	µCi/mL	2E-05
Uranium-232 (U-232)	µCi/mL	1E-07
Uranium-233 (U-233)	µCi/mL	5E-07
Uranium-234 (U-234)	µCi/mL	5E-07
Uranium-235 (U-235)	µCi/mL	6E-07
Uranium-236 (U-236)	µCi/mL	5E-07
Uranium-238 (U-238)	µCi/mL	6E-07
Plutonium-238 (Pu-238)	µCi/mL	4E-08
Plutonium-239 (Pu-239)	µCi/mL	3E-08
Plutonium-240 (Pu-240)	µCi/mL	3E-08
Americium-241 (Am-241)	µCi/mL	3E-08

[a] DCG: Derived Concentration Guide. DCGs are established in DOE Order 5400.5 and are defined as the concentration of a radionuclide that, under conditions of continuous exposure for one year by one exposure mode, would result in an effective dose equivalent of 100 mrem (1mSv).

[b] Because there are no DCGs for gross alpha and gross beta concentrations, the DCGs for the most restrictive alpha and beta emitters at the WVDP, americium-241 and strontium-90 (3E-08 and 1E-06 µCi/mL, respectively) are used as a conservative basis for comparison at locations for which there are no radionuclide-specific data, in which case a more appropriate DCG may be applied.